

Bismarck-Damestown No. 2 230 Kv 1  
 NAME OF LINE, Trans. Line ~ Power &  
 Telephone Lines Clearances.  
 PARTY: Cox, C.R.

DATE February 6 1959

STA.	DIST.	HOR. ANGLE	MAG. BEARING	VERT. ANGLE	ELEV.
------	-------	------------	--------------	-------------	-------

(Initial pages of transit book used for a complete and accurate explanation of procedure used to obtain the survey notes.)

Note:

The distance between the two center line P.O.T.s was obtained by chaining.

All distances from P.O.T. to base of pole obtained by chaining, as well as the distance to the structures to the right and left of survey intersection P.O.T.

Vertical angles observed normal and inverted to the highest wire above the ground at center line and structure to the right and left of center line.

Temperature at time of observation determined by use of a thermometer.

Address of utility obtained by inquiry of residents of the area, as well as contact of utility offices in various cities and towns.